


Building Safety Certificate

Certified that the building of "Namdhari Dehli Public School, Chamukha, PO. Sehli, Tehsil-SunderNagar, Distt. Mandi H.P. has been constructed as per approved plan and a design as per IS code.

Authorized signatory 
"Namdhari Dehli Public School, Chamukha, PO. Sehli, Tehsil-SunderNagar, Distt. Mandi H.P.

Certified that the building of "Namdhari Dehli Public School, Chamukha, PO. Sehli, Tehsil-SunderNagar, Distt. Mandi H.P. has been got inspected through Assistant Engineer, Suket Sub-Division, H.P.P.W.D. Suket along with Junior Engineer Ghanganoo Section on 09-02-2026 and found that the building is RCC framed structure and six storeys consisting of one basement & five storeys including ground floor is under construction. Schooling activities are being carried in ground, of including three basement 1st, 2nd and 3rd floor. Public Works Department has never supervised this building during construction at any stage. No detailed structural analysis and drawings in seismic and non-seismic condition are available/were provided to check the safety of building. Foundation depth, quality and quantity of material used & cement concrete ratio used is not known to HP.PWD. However Presently by visual inspection the said building seems safe for running the College for the academic session 2026-27 in normal conditions except in case of natural calamities i.e. earth quake, cloud burst, flood, unequal settlement etc. No further construction should be raised on this building.


Executive Engineer,
Sunder Nagar Division,
HPPWD Sunder Nagar.

No. PW-SNR-WA-(B-15) Building-2025-

13091.92

Dated: 13-02-2026

Copy to the Principal "Namdhari Dehli Public School, Chamukha, Tehsil-SunderNagar, Distt. Mandi H.P.

Copy to the Assistant Engineer, Suket Sub-Division, HP.PWD, Suket for information and necessary action. This is w.r.t. his office letter No. 1095 dated 09-02-2026.


Executive Engineer,
Sunder Nagar Division,
HPPWD Sunder Nagar.